

		<h2 style="text-align: center;">IECEx Certificate of Conformity</h2>	
<p><b>INTERNATIONAL ELECTROTECHNICAL COMMISSION</b>  <b>IEC Certification Scheme for Explosive Atmospheres</b>  <small>for rules and details of the IECEx Scheme visit <a href="http://www.iecex.com">www.iecex.com</a></small></p>			
Certificate No.:	IECEx PRE 17.0003X	Issue No.:	0
Status:	Current	Certificate history: .....	
Date of Issue:	2017-05-05	Page 1 of 3	
Applicant:	<b>Mistras Group</b> 195 Clarksville Road Princeton Junction New Jersey 08550-503 <b>United States of America</b>		
Equipment:	<b>ISPKxxI, ISPKxxUC and ISPKxxIUC with a 1281 or 1281-LP interface</b> <i>Optional accessory:</i>		
Type of Protection:	<b>Ex ia IIC T6-T3 Ga/ [Ex ia] IIC T85C-T200C [Ex ia] IIC Da</b>		
Marking:	Barrier Interface: 1281-5015 Um=250V Uo=5,88V Io=0,297A Po=0,44W Lo=0,35 mH Co=43 uF		
Approved for issue on behalf of the IECEx Certification Body:	Asle Kaastad		
Position:	Certification Manager		
Signature: (for printed version)	_____		
Date:	_____		
<p>1. This certificate and schedule may only be reproduced in full.          2. This certificate is not transferable and remains the property of the issuing body.          3. The Status and authenticity of this certificate may be verified by visiting the <a href="http://www.iecex.com">Official IECEx Website</a>.</p>			
Certificate issued by:			
DNV Nemko Presafe AS Gaustadalleen 30 P.O.Box 73 Blindern 0314 Oslo Norway		A DNV & NEMKO COMPANY	



## IECEx Certificate of Conformity

Certificate No.: IECEx PRE 17.0003X

Date of Issue: 2017-05-05

Issue No.: 0

Page 2 of 3

Manufacturer: **Mistras Group**  
195 Clarksville Road  
Princeton Junction  
New Jersey 08550-503  
**United States of America**

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

**IEC 60079-0 : 2011** Explosive atmospheres - Part 0: General requirements

Edition: 6.0

**IEC 60079-11 : 2011** Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "I"

Edition: 6.0

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

#### TEST & ASSESSMENT REPORTS:



*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

##### Test Report:

[NO/PRE/EXTR17.0004/00](#)

##### Quality Assessment Report:

[GB/SIR/QAR08.0008/05](#)

		<b>IECEX Certificate of Conformity</b>
Certificate No.:	IECEX PRE 17.0003X	Issue No.: 0
Date of Issue:	2017-05-05	Page 3 of 3
<b>Schedule</b>		
<b>EQUIPMENT:</b> <i>Equipment and systems covered by this certificate are as follows:</i>		
<p>The equipment consists of a series of ISPKxxI &amp; ISPxxIUC sensors with a 1281 barrier/preamp interface. The barrier interface supplies the sensors with an intrinsically safe signal. The Barrier/Preamp Interface also detects AST signal from the standard AE system and sends it to the preamplifier/sensors where the sensors will generate tone bursts to send back to the AE system through the barrier. The pre-amplified can be integrated into the sensor or installed as a separate unit. See annex for more details.</p>		
<b>SPECIFIC CONDITIONS OF USE: YES as shown below:</b>		
<p>The instructions indicate all the necessary information to ensure the installation minimizes the risk from electrostatic discharge. Sensors with aluminium enclosures shall be installed as to protect them from ignition hazards due to impact.</p>		